


Instruction Sheet
安裝說明
安裝說明

Analog Input Module

類比輸入模組
模拟输入模块6. Mounting hole of the expansion unit
7. Nameplate
13. DC power input
14. Expansion port

External Wiring and Terminal Layout



Note 1: Please isolate analog input and other power wiring.

Note 2: If current signal is connected, V4+ and I4+ terminals must be short-circuited, and form a circuit with COM4.

Note 3: If noise is significant, please connect FG to grounding.

Note 4: Please connect \oplus terminal of power module and \oplus terminal of analog input module to system earth point and make system earth point be grounding or connects to machine cover.

Note 5: If noise interferes from loaded input wiring terminal is significant, please connect a capacitor with 0.1 ~ 0.47μF 25V for noise filtering.

Warning: DO NOT wire to the No function terminal ●.

② Specifications

■ Functions

Analog/Digital (4/A/D) module	Voltage input	Current input
Power supply voltage	24VDC (20.4VDC ~ 28.8VDC) (-15% ~ +20%)	
Analog input channel	4 channel/each module	
Analog input range	$\pm 10V$	$\pm 20mA$
Digital conversion range	$\pm 8,000$ (14 bits)/ $\pm 32,000$ (16 bits)	$\pm 4,000$ (13 bits)/ $\pm 16,000$ (15 bits)
Resolution	14 bits ($1_{LSB}=1.25mV$) 16 bits ($1_{LSB}=312.5\mu V$)	13 bits ($1_{LSB}=5\mu A$) 15 bits ($1_{LSB}=1.25\mu A$)
Input impedance	> 200kΩ	250Ω
Overall accuracy	$\pm 0.5\%$ of full scale of 25°C (77°F). $\pm 1\%$ of full scale during 0 ~ 55°C (32 ~ 131°F)	
Response time	3ms × channels	
Isolation method	It has isolation between digital area and analog area. There is no isolation among channels.	
Absolute input range	$\pm 15V$	$\pm 32mA$
Digital data format	16-bit 2's complement	
Average function	Yes (CR#2 ~ CR#5 can be set and setting range is K1 ~ K20)	
Self diagnose function	Upper and lower bound detection/channels	



⚠ Warning ENGLISH

EN ✓ DVP04AD-S2 is an OPEN-TYPE device. It should be installed in a control cabinet free of airborne dust, humidity, electric shock and vibration. To prevent non-maintenance staff from operating DVP04AD-S2, or to prevent an accident from damaging DVP04AD-S2, the control cabinet in which DVP04AD-S2 is installed should be equipped with a safeguard. For example, the control cabinet in which DVP04AD-S2 is installed can be unlocked with a special tool or key.

EN ✗ DO NOT connect AC power to any of I/O terminals, otherwise serious damage may occur. Please check all wiring again before DVP04AD-S2 is powered up. After DVP04AD-S2 is disconnected, Do NOT touch any terminals in a minute. Make sure that the ground terminal \ominus on DVP04AD-S2 is correctly grounded in order to prevent electromagnetic interference.

FR ✗ DVP04AD-S2 est un module OUVERT. Il doit être installé que dans une enceinte protectrice (boîtier, armoire, etc.) saine, dépourvue de poussière, d'humidité, de vibrations et hors d'atteinte des chocs électriques. La protection doit éviter que les personnes non habilitées à la maintenance puissent accéder à l'appareil (par exemple, une clef ou un outil doivent être nécessaire pour ouvrir la protection).

FR ✗ Ne pas appliquer la tension secteur sur les bornes d'entrées/Sorties, ou l'appareil DVP04AD-S2 pourra être endommagé. Merci de vérifier encore une fois le câblage avant la mise sous tension du DVP04AD-S2. Lors de la déconnection de l'appareil, ne pas toucher les connecteurs dans la minute suivante. Vérifier que la terre est bien reliée au connecteur de terre \ominus afin d'éviter toute interférence électromagnétique.


① Introduction

■ Model Explanation & Peripherals

- Thank you for choosing DELTA PLC DVP Series. The analog input module receives external 4-point analog signal input (voltage or current) and converts it into 14-bit/16-bit digital signal. The analog input module of DVP04AD-S2 series can read/write the data of analog input module by using instructions FROM/TO via DVP-PLC SS/SX/SC/SV series MPU program. There are 49 CR (Control Register, each register has 16-bit) in each module.

- Users can select input from voltage or current via wiring. Voltage input range is $\pm 10VDC$ (14-bit resolution: 1.25mV; 16-bit resolution: 312.5μV). Current input range is $\pm 20mA$ (13-bit resolution: 5μA; 15-bit resolution: 1.25μA).

■ Product Profile & Outline




Analog/Digital (4/A/D) module	Voltage input	Current input
Communication mode (RS-485)	Modbus ASCII/RTU Mode. Communication baud rate of 4,800/9,600/19,200/38,400/57,600/115,200. For ASCII mode, date format is 7 bits, even, 1 stop bit (7, E, 1), while RTU mode, date format is 8 bits, even, 1 stop bit (8, E, 1). The RS-485 is disabled when the DVP04AD-S2 is connected in series with MPU.	
Connect to DVP-PLC MPU in series	If DVP04AD-S2 modules are connected to MPU, the modules are numbered from 0 ~ 7, 0 is the closest and 7 is the furthest to the MPU. 8 modules is the max and they do not occupy any digital I/O points of the MPU.	
Power specification		
Max. rated consuming power	24VDC (20.4VDC ~ 28.8VDC) (-15% ~ +20%), 2W, supply from external power.	
Environment condition	1. Operation: 0°C ~ 55°C (temperature), 5 ~ 95% (humidity), pollution degree 2 2. Storage: -25°C ~ 70°C (temperature), 5 ~ 95% (humidity)	
Vibration/shock immunity	Standard: IEC61131-2, IEC68-2-6 (TEST Fc)/IEC61131-2 & IEC68-2-27 (TEST Ea)	

③ Installation and Wiring


DIN Rail Installation

The DVP-PLC can be secured to a cabinet by using the DIN rail that is 35mm high with a depth of 7.5mm. When mounting the PLC on the DIN rail, be sure to use the end bracket to stop any side-to-side motion of the PLC, thus to reduce the chance of the wires being pulled loose. On the bottom of the PLC is a small retaining clip. To secure the PLC to the DIN rail, place it onto the rail and gently push up on the clip and gently pull the PLC away from the DIN rail. Please see the figure on the right.

Wiring



1. Use 22-16AWG (1.5mm) single or multiple core wire on I/O wiring terminals. The specification of the terminal is shown in the figure on the left hand side. The PLC terminal screws shall be tightened to 1.95kg-cm (1.7 in-lbs). Use 60/75°C copper wires only.
2. DO NOT place the I/O signal wires and power supply wire in the same wiring duct.



④ CR (Control Register)

CR #	RS-485 parameter address	Latched	Register name	b15 b14 b13 b12 b11 b10 b9 b8 b7 b6 b5 b4 b3 b2 b1 b0	
#0	H'4000	O R	Model type	Bit switch (CR#1) CH4 CH3 CH2 CH1	
#1	H'4001	O R/W	Input mode setting	System used, data length is 8 bits (b7 ~ b0), DVP04AD-S2 model code=H'90. User can read the data from program to check if there is expansion module.	
#2	H'4002	O R/W	CH1 average times	Input mode setting: factory setting is H'0000. Mode 0: input voltage mode (-10V ~ +10V). Mode 1: input voltage mode (-6V ~ +10V). Mode 2: input current mode (-12mA ~ +20mA). Mode 3: input current mode (-20mA ~ +20mA). Mode 4: none use.	

CR#1: CR#1 is used to set 4 internal channels working mode of analog input module. Every channel has four modes to set that can be set individually. For example: if users want set CH1 to mode 0 (b2 ~ b0 = 000), CH2 to mode 1 (b5 ~ b3 = 001), CH3 to mode 2 (b8 ~ b6 = 010), and CH4 to mode 3 (b11 ~ b9 = 011), they have to set CR#1 to H'0688. Users can switch between the 16-bit channels or 16-bit channels by setting the higher bits (b15 ~ b12). If the four channels are 16-bit channels, b15~b12 = 1111. Default setting: The four channels are 14-bit channels, b15~b12 = 0000.

#2 | H'4002 | O R/W | CH1 average times | Average times setting of channel CH1 ~ CH2.

CR #	RS-485 parameter address	Latched	Register name	b15 b14 b13 b12 b11 b10 b9 b8 b7 b6 b5 b4 b3 b2 b1 b0	
#3	H'4003	O R/W	CH2 average times	Bit switch (CR#1) CH4 CH3 CH2 CH1	
#4	H'4004	O R/W	CH3 average times	Setting range is K1 ~ K20 and factory setting is K10.	
#5	H'4005	O R/W	CH4 average times	Average times setting of channel CH3 ~ CH4.	
#6	H'4006	X R	CH1 average times	Setting range is K1 ~ K20 and factory setting is K10.	
#7	H'4007	X R	CH2 average times	Display average value of CH1 ~ CH4 input signal.	
#8	H'4008	X R	CH3 average times	Display present value of CH1 ~ CH4 input signal.	
#9	H'4009	X R	CH4 average times	Display present value of CH1 ~ CH4 input signal.	
#10	H'400C	X R	CH1 present value	Display present value of CH1 ~ CH4 input signal.	
#11	H'400D	X R	CH2 present value	Display present value of CH1 ~ CH4 input signal.	
#12	H'400E	X R	CH3 present value	Display present value of CH1 ~ CH4 input signal.	
#13	H'400F	X R	CH4 present value	Display present value of CH1 ~ CH4 input signal.	
#14	H'4012	O R/W	To adjust OFFSET value of CH1	GAIN setting of CH1 ~ CH4.	
#15	H'4013	O R/W	To adjust OFFSET value of CH2	Factory setting is K0 and unit is LSB.	
#16	H'4014	O R/W	To adjust OFFSET value of CH3	GAIN setting of CH1 ~ CH4.	
#17	H'4015	O R/W	To adjust OFFSET value of CH4	Factory setting is K4,000 and unit is LSB.	
#18	H'4018	O R/W	To adjust GAIN value of CH1	GAIN setting of CH1 ~ CH4.	
#19	H'4019	O R/W	To adjust GAIN value of CH2	Factory setting is K4,000 and unit is LSB.	
#20	H'401A	O R/W	To adjust GAIN value of CH3	GAIN setting of CH1 ~ CH4.	
#21	H'401B	O R/W	To adjust GAIN value of CH4	Factory setting is K4,000 and unit is LSB.	
#22	H'401C	X R	Error status	It is the data register to save all error status. Please refer to error code chart for detail.	
#30	H'401E	X R	Error status	It is the data register to save all error status. Please refer to error code chart for detail.	
#31	H'401F	O R/W	Communication address setting	Setting RS-485 communication address. Setting range is 01 ~ 254 and factory setting is K1.	

Voltage input mode	
14 bits	16 bits
GAIN=5V (4,000 _{LSB}), OFFSET=0V (0 _{LSB})	GAIN=5V (16,000 _{LSB}), OFFSET=0V (0 _{LSB})
Mode 0 of CR#1:	Mode 1 of CR#1:
GAIN=6V (4,800 _{LSB}), OFFSET=2V (1,600 _{LSB})	GAIN=6V (19,200 _{LSB}), OFFSET=2V (6,400 _{LSB})
GAIN:	GAIN:
Voltage input value gotten when the digital output value is 4,000	Voltage input value gotten when the digital output value is 16,000
OFFSET:	OFFSET:
V	

